



181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Trailers at High School
Caruso Pre K
Keansburg High School
Caruso Elementary School
Joseph Bolger Middle School

Performed For:

Keansburg School District
John Furnback
100 Palmer Place
Keansburg, NJ 07734

Prepared By:

LEW Corporation
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>

Inspection Date: 5/21/2022 10:31 AM
Project Number: 220157

Table of Contents

Contact Information.....	3
Introduction	4
Sampling Methodology	4
Drinking Water Results	5
Recommendations	6
Additional Recommendations	7

Appendices


Appendix A	Exceedances
Appendix B	Recommendations
Appendix C	All results
Appendix D	Floor Plan(S)
Appendix E	Laboratory Data

Contact Information

Agency

Client Contact:	John Furnback
Client Name:	Keansburg School District
Street Address	100 Palmer Place Keansburg, NJ 07734
Phone Number:	(732) 787-2007

Risk Assessor(s)

Site Assessor(s):	Robert Carlucci
License:	NJDOH #015821
Signature:	
Date:	June 9, 2022
E-Mail	rcarlucchi@lewenvironmental.com

Firm

Organization:	LEW Corporation
Certification #:	NJDCA 00015 E
Street:	181 US Hwy 46
City, State & Zip:	Mine Hill, NJ 07803
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Environmental Hazard Services, LLC
Street:	7469 Whitepine Road
City, State & Zip:	Richmond, VA 23237
NJDEP Certification #	VA008
Phone Number:	800-347-4010

Introduction

LEW Corporation was contracted by Keansburg School District to test for the presence of lead in drinking water in four schools in the district.

Sampling Methodology

LEW Corporation followed the July 13, 2016 amendments to NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.

Drinking Water Results

On May 21st & 22nd 2022, Robert Carlucci of LEW Corporation collected the following number of water samples:

Trailers at High School

- 4 first draw samples collected
- 2 samples above the 15ppb action level

Caruso Pre K

- 13 first draw samples
- 0 samples above the 15ppb action level

Keansburg High School

- 16 first draw samples
- 1 samples above the 15ppb action level

Caruso Elementary School

- 51 first draw samples
- 1 samples above the 15ppb action level

Joseph Bolger Middle School

- 30 first draw samples
- 2 samples above the 15ppb action level

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix E.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

School	Sample Location	Reason for not testing
Trailers	Sink Bubbler Room 12	Turned Off
Trailers	Sink Bubbler Room 8	Removed
Trailers	Sink Bubbler Room 5	Removed
Trailers	Sink Bubbler Room 3	Removed
Trailers	Sink Bubbler Room 1	Removed
Trailers	Sink Bubbler Room 2	Removed
Joseph Bolger MS	Water Cooler by IM-420 Right	Not Working
Joseph Bolger MS	Water Cooler by Faculty Room Right	Not Working
Joseph Bolger	Trailer #2 Water Cooler	No longer exists

MS		
Joseph Bolger MS	Sink 5 Home Ec	Removed
Joseph Bolger MS	Water Cooler by 423 Right	Not Working
Joseph Bolger MS	Water Cooler by 425 Right	Not Working
Joseph Bolger MS	Water Cooler by 425 Left	Not Working
Joseph Bolger MS	Water Cooler by 305 Right	Not Working
Caruso Elementary	Bottle Fill by gym	Not Working
Caruso Elementary	Water Fountain by Playground	Not Working
Caruso Elementary	Ice Machine Nurse Office	Not Working
Caruso Elementary	Sink in A-111	Hand wash only
Keansburg HS	Bubbler in KAPA	Could not locate
Keansburg HS	Water Cooler in Girls Locker	Not Working
Keansburg HS	Water Cooler by Teachers Left	Not Working
Keansburg HS	Water Cooler by teachers Right	Not Working
Keansburg HS	Water Cooler by Boys Locker	Not Working
Keansburg HS	Bubbler by Room 204	Not Working
Keansburg HS	Sink on backwall Right	Not Working

Recommendations

Those outlets where the first draw sample tested below 15ppb are not considered to be elevated and no mitigation is necessary.

For those outlets where the first draw sample exceeds 15ppb the following steps are recommended:

- 1) Immediately discontinue use of the outlets.
- 2) Conduct second draw (flush) samples on these outlets to further delineate source of contamination.

A complete list of recommendations per outlet can be found in Appendix B.

Additional Recommendations

- 1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
- 2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sample.
- 3) Comply with all requirements set forth in NJAC 6A:26.

Appendix A Exceedances

Building	Date Collected	Date Analyzed	Sample ID	Sample Location	Concentration ppB
Trailer at HS	5/21/2022	6/01/2022	PMR-WF-RM13	Water Fountain in Room 13	26.8
Trailer at HS	5/21/2022	6/1/2022	PMR-WF-RM9	Water Fountain in Room 9	108
Keansburg HS	5/21/2022	6/1/2022	KHS-PF-Kit	Kitchen Pot Filler	35.3
Caruso Elementary School	5/21/2022	6/1/2022	CE-S1-Kit	Sink 1 in Kitchen	19.9
Joseph Bolger MS	5/21/2022	6/1/2022	JBM-PF-Kit	Pot Filler Kitchen	53.5
Joseph Bolger MS	5/21/2022	6/1/2022	JMB-S6-HE	Sink 6 Home Ec	34.2

Appendix B Recommendations

Building	Sample Location	PPB	Recommendations
Trailer at High School	Water Fountain Room 13	26.8	<ol style="list-style-type: none"> 1) Immediately discontinue use of the outlet. 2) Take outlet off line, replace faucet or use as hand wash only.
Trailer at High School	Water Fountain Room 9	108	<ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Take outlet off line, replace faucet or use as hand wash only.
Keansburg HS	Pot Filler in Kitchen	35.3	<ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Take outlet off line, replace faucet or use as hand wash only..
Caruso Elementary	Sink 1 in Kitchen	19.9	<ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Take outlet off line, replace faucet or use as hand wash only..
Joseph Bolger MS	Pot Filler in Kitchen	53.5	<ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Take outlet off line, replace faucet or use as hand wash only..
Joseph Bolger MS	Sink 6 in Home EC	34.2	<ol style="list-style-type: none"> 1) Immediately discontinue use of the outlets. 2) Take outlet off line, replace faucet or use as hand wash only

Appendix C All Results

Project Name	Client Sample	Sample Description	Concentration (ug/L)
Trailers at High School	PMR-WF-RM13	WATER FOUNTAIN IN ROOM 13	26.8
Trailers at High School	PMR-WF-RM10	WATER FOUNTAIN IN ROOM 10	10.7
Trailers at High School	PMR-WF-RM9	WATER FOUNTAIN IN ROOM 9	108
Trailers at High School	PMR-WF-RM4	WATER FOUNTAIN IN ROOM 4	2.83
Trailers at High School	PMR-S-SR	SINK IN SUNROOM	<1.00
Caruso Pre K	CPS-SB-RM1	BUBBLER IN ROOM 1	5.35
Caruso Pre K	CPS-SB-RM3	BUBBLER IN ROOM 3	<1.00
Caruso Pre K	CPS-SB-RM5	BUBBLER IN ROOM 5	2.32
Caruso Pre K	CPS-S-TL	SINK IN TEACHER'S LOUNGE	1.22
Caruso Pre K	CPS-S-NO	SINK IN NURSE'S OFFICE	<1.00
Caruso Pre K	CPS-SB-RM11	BUBBLER IN ROOM 11	<1.00
Caruso Pre K	CPS-SB-RM2	BUBBLER IN ROOM 2	1.66
Caruso Pre K	CPS-SB-RM4	BUBBLER IN ROOM 4	10.9
Caruso Pre K	CPS-SB-RM6	BUBBLER IN ROOM 6	2.03
Caruso Pre K	CPS-SB-RM7	BUBBLER IN ROOM 7	<1.00
Caruso Pre K	CPS-SB-RM8	BUBBLER IN ROOM 8	<1.00
Caruso Pre K	CPS-SB-RM10	BUBBLER IN ROOM 10	<1.00
Caruso Pre K	CPS-S-SR	SUN ROOM SINK	<1.00
Keansburg High School	KHS-S-MO	MAIN OFFICE SINK	<1.00
Keansburg High School	KHS-S-NO	NURSE OFFICE SINK	<1.00
Keansburg High School	KHS-WF-105	WATER FOUNTAIN BY 105	1.94
Keansburg High School	KHS-WC-105	WATER COOLER BY 105	<1.00
Keansburg High School	KHS-S-RM110	SINK IN ROOM 110	2.48
Keansburg High School	KHS-WFR-162	WATER FOUNTAIN BY 162 RIGHT	3.93
Keansburg High School	KHS-WFL-162	WATER FOUNTAIN BY 162 LEFT	5.02
Keansburg High School	KHS-S1-KIT	SINK 1 IN KITCHEN	<1.00
Keansburg High School	KHS-S2-KIT	SINK 2 IN KITCHEN	<1.00
Keansburg High School	KHS-S3-KIT	SINK 3 IN KITCHEN	1.75
Keansburg High School	KHS-IM-BL	ICE MACHINE IN BOY'S LOCKER	<1.00
Keansburg High School	KHS-WC-204	WATER COOLER BY ROOM 204	1.10

Keansburg High School	KHS-WC-CAFE	WATER COOLER IN CAFETERIA	2.70
Keansburg High School	KHS-S-TL	TEACHER'S LOUNGE SINK	<1.00
Keansburg High School	KHS-PF-KIT	POT FILLER IN KITCHEN	35.3
Keansburg High School	KHS-S-SR	SUNROOM SINK	<1.00
Caruso Elementary School	CE-S-C110	SINK IN C110	<1.00
Caruso Elementary School	CE-FP1-KIT	SINK IN KITCHEN	<1.00
Caruso Elementary School	CE-PF-KIT	POT FILLER IN KITCHEN	<1.00
Caruso Elementary School	CE-S1-KIT	SINK 1 IN KITCHEN	19.9
Caruso Elementary School	CE-S2-KIT	SINK 2 IN KITCHEN	<1.00
Caruso Elementary School	CE-S3-KIT	SINK 3 IN KITCHEN	1.06
Caruso Elementary School	CE-LS-KIT	LEFT DISHWASH SINK	<1.00
Caruso Elementary School	CE-RS-KIT	RIGHT DISHWASH SINK	<1.00
Caruso Elementary School	CE-SB-B102	BUBBLER IN ROOM B102	<1.00
Caruso Elementary School	CE-SB-B106	BUBBLER IN ROOM B106	<1.00
Caruso Elementary School	CE-SB-B108	BUBBLER IN ROOM B108	<1.00
Caruso Elementary School	CE-WC-100E	WATER COOLER BY 100E	<1.00
Caruso Elementary School	CE-BF-100E	BOTTLE FILL BY 100E	<1.00
Caruso Elementary School	CE-WF-100E	WATER FOUNTAIN BY 100E	<1.00
Caruso Elementary School	CE-SB-B116	BUBBLER IN ROOM B116	<1.00
Caruso Elementary School	CE-WF-A105	WATER FOUNTAIN IN A105	<1.00
Caruso Elementary School	CE-WC-A105	WATER COOLER IN A105	<1.00
Caruso Elementary School	CE-BF-A105	BOTTLE FILL IN A105	<1.00
Caruso Elementary School	CE-S-A104	SINK IN A104	4.09
Caruso Elementary School	CE-WC-GYM	WATER COOLER IN GYM	<1.00
Caruso Elementary School	CE-WC-C104	WATER COOLER AT C104	<1.00
Caruso Elementary School	CE-WF-C104	WATER FOUNTAIN AT C104	<1.00
Caruso Elementary School	CE-S-C104	SINK IN C104	<1.00
Caruso Elementary School	CE-SB-B101	BUBBLER IN B101	<1.00
Caruso Elementary School	CE-SB-B103	BUBBLER IN B103	<1.00
Caruso Elementary School	CE-SB-B105	BUBBLER IN B105	<1.00
Caruso Elementary School	CE-SB-B107	BUBBLER IN B107	<1.00
Caruso Elementary School	CE-WF-A107	WATER FOUNTAIN BY A107	<1.00
Caruso Elementary School	CE-WC-A107	WATER COOLER BY A107	<1.00
Caruso Elementary School	CE-NS1-A110	SINK IN NURSE OFFICE	<1.00
Caruso Elementary School	CE-NS2-A110	SINK 2 IN NURSE OFFICE	7.67
Caruso Elementary School	CE-NS3-A110	SINK 3 IN NURSE OFFICE	1.02
Caruso Elementary School	CE-WF-B200L	WATER FOUNTAIN BY B200L	<1.00
Caruso Elementary School	CE-WC-B200L	WATER COOLER BY B200L	<1.00
Caruso Elementary School	CE-BF-B200L	BOTTLE FILL BY B200L	<1.00
Caruso Elementary School	CE-WC-B200G	WATER COOLER BY B200G	<1.00
Caruso Elementary School	CE-WF-B200G	WATER FOUNTAIN BY B200G	<1.00
Caruso Elementary School	CE-BF-B200G	BOTTLE FILL BY B200G	<1.00
Caruso Elementary School	CE-S-B110	SINK IN B110	1.65
Caruso Elementary School	CE-WC-B300G	WATER COOLER BY B300G	<1.00
Caruso Elementary School	CE-WF-B300G	WATER FOUNTAIN BY B300G	<1.00

Caruso Elementary School	CE-BF-B300G	BOTTLE FILL BY B300G	<1.00
Caruso Elementary School	CE-WF-B300L	WATER FOUNTAIN BY B300L	<1.00
Caruso Elementary School	CE-WC-B300L	WATER COOLER BY B300L	<1.00
Caruso Elementary School	CE-BF-B300L	BOTTLE FILL BY B300L	<1.00
Caruso Elementary School	CE-BF-A107	BOTTLE FILL BY A107	<1.00
Caruso Elementary School	CE-BF-C104	BOTTLE FILL BY C104	<1.00
Caruso Elementary School	CE-S-A105	SINK IN A105	1.06
Caruso Elementary School	CE-WF-GYM	WATER FOUNTAIN BY GYM	<1.00
Caruso Elementary School	CE-SB-B104	SINK BUBBLER IN B104	<1.00
Caruso Elementary School	CE-S-SR	SUN ROOM	<1.00
Joseph Bolger Middle School	JMB-S-NO	SINK IN NURSE OFFICE	<1.00
Joseph Bolger Middle School	JMB-IM-NO	ICE MACHINE IN NURSE OFFICE	<1.00
Joseph Bolger Middle School	JMB-WC-ONO	WATER COOLER OUTSIDE NURSE	2.27
Joseph Bolger Middle School	JMB-WC-AO	WATER COOLER BY ADMIN OFFICE	2.46
Joseph Bolger Middle School	JMB-WCL-420	WATER COOLER LEFT BY ROOM 420	<1.00
Joseph Bolger Middle School	JMB-WCL-501	WATER COOLER LEFT BY 501	4.52
Joseph Bolger Middle School	JMB-WCR-501	WATER COOLER RIGHT BY 501	1.24
Joseph Bolger Middle School	JMB-WCL-531	WATER COOLER LEFT BY 531	<1.00
Joseph Bolger Middle School	JMB-WCR-531	WATER COOLER RIGHT BY 531	2.41
Joseph Bolger Middle School	JMB-WCR-413	WATER COOLER RIGHT BY 413	<1.00
Joseph Bolger Middle School	JMB-WCL-413	WATER COOLER LEFT BY 413	<1.00
Joseph Bolger Middle School	JMB-WCL-FAC	WATER COOLER LEFT BY FACULTY	<1.00
Joseph Bolger Middle School	JMB-S1-KIT	WASH SINK LEFT KITCHEN	<1.00
Joseph Bolger Middle School	JMB-S2-KIT	WASH SINK RIGHT KITCHEN	<1.00
Joseph Bolger Middle School	JMB-S3-KIT	BACK WALL SINK KITCHEN	<1.00
Joseph Bolger Middle School	JMB-PF-KIT	POT FILLER KITCHEN	53.5
Joseph Bolger Middle School	JMB-FP-KIT	FOOD PREP TABLE SINK KITCHEN	1.60
Joseph Bolger Middle School	JMB-WCL-204	WATER COOLER LEFT BY 204	<1.00
Joseph Bolger Middle School	JMB-WCR-204	WATER COOLER RIGHT BY 204	2.10
Joseph Bolger Middle School	JMB-WCR-233	WATER COOLER RIGHT BY 233	2.23
Joseph Bolger Middle School	JMB-WCL-233	WATER COOLER LEFT BY 233	<1.00

Joseph Bolger Middle School	JMB-S1-HE	HOME EC SINK 1	1.07
Joseph Bolger Middle School	JMB-S2-HE	HOME EC SINK 2	<1.00
Joseph Bolger Middle School	JMB-S3-HE	HOME EC SINK 3	4.14
Joseph Bolger Middle School	JMB-S4-HE	HOME EC SINK 4	3.49
Joseph Bolger Middle School	JMB-S6-HE	HOME EC SINK 6	34.2
Joseph Bolger Middle School	JMB-S7-HE	HOME EC SINK 7	2.64
Joseph Bolger Middle School	JMB-WCL-423	WATER COOLER BY 423 LEFT	2.44
Joseph Bolger Middle School	JMB-WCL-305	WATER COOLER BY 305 LEFT	2.34
Joseph Bolger Middle School	JMB-S-SR	SUN ROOM	<1.00

Appendix D Floor Plan(s)



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 22-05-04575

Received Date: 05/24/2022
Reported Date: 06/01/2022
Sampled By: Robert Carlucci
Tech Certification #:

Project/Test Address: 220157; Trailers at High School; 140 Port Monmouth Road; Keansburg, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04575-001	PMR-WF-RM13	05/21/2022	WATER FOUNTAIN IN ROOM 13	26.8	06/01/2022	
22-05-04575-002	PMR-WF-RM10	05/21/2022	WATER FOUNTAIN IN ROOM 10	10.7	06/01/2022	
22-05-04575-003	PMR-WF-RM9	05/21/2022	WATER FOUNTAIN IN ROOM 9	108	06/01/2022	
22-05-04575-004	PMR-WF-RM4	05/21/2022	WATER FOUNTAIN IN ROOM 4	2.83	06/01/2022	
22-05-04575-005	PMR-S-SR	05/21/2022	SINK IN SUNROOM	<1.00	06/01/2022	

Method: EPA 200.8
Analyst: Allison Rodriguez
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

22-05-04575



Due Date:

06/01/2022

(Wednesday)

AE

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address:

Trailers at Highschool

City/State/Zip:

146 Port Monmouth Rd. Leesburg

(Required)

(Required)

Project #: 220157

Sampled By: Robert Carlsen

License # (if Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (if Applicable):

X

5 DAY TURNAROUND

6 DAY TURNAROUND

10 DAY TURNAROUND

15 DAY TURNAROUND

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
1	PME-WF-QMIB	Water Fountain in Room 13	5-21-22	11:00 AM	X					
2	PME-WF-QMIB	Water Fountain in Room 10								
3	PME-WF-QMIB	Water Fountain in Room 9								
4	PME-WF-QMIB	Water Fountain in Room 4								
5	PME-S-SQ	Sink in Sun Room								
6										
7										
8										
9										
10										

Released by:

Robert Carlsen

Signature:

[Signature]

Date/Time:

5-21-22

1 PM

Released by:

AKANDOL

Signature:

[Signature]

Date/Time:

5/24/22

11:33 AM



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 22-05-04580

Received Date: 05/24/2022
Reported Date: 06/01/2022
Sampled By: Robert Carlucci
Tech Certification #:

Project/Test Address: 220157; Caruso Pre K; 161 Ramsey Avenue; Keansburg, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04580-001	CPS-SB-RM1	05/21/2022	BUBBLER IN ROOM 1	5.35	06/01/2022	
22-05-04580-002	CPS-SB-RM3	05/21/2022	BUBBLER IN ROOM 3	<1.00	06/01/2022	
22-05-04580-003	CPS-SB-RM5	05/21/2022	BUBBLER IN ROOM 5	2.32	06/01/2022	
22-05-04580-004	CPS-S-TL	05/21/2022	SINK IN TEACHER'S LOUNGE	1.22	06/01/2022	
22-05-04580-005	CPS-S-NO	05/21/2022	SINK IN NURSE'S OFFICE	<1.00	06/01/2022	
22-05-04580-006	CPS-SB-RM11	05/21/2022	BUBBLER IN ROOM 11	<1.00	06/01/2022	
22-05-04580-007	CPS-SB-RM2	05/21/2022	BUBBLER IN ROOM 2	1.66	06/01/2022	
22-05-04580-008	CPS-SB-RM4	05/21/2022	BUBBLER IN ROOM 4	10.9	06/01/2022	
22-05-04580-009	CPS-SB-RM6	05/21/2022	BUBBLER IN ROOM 6	2.03	06/01/2022	
22-05-04580-010	CPS-SB-RM7	05/21/2022	BUBBLER IN ROOM 7	<1.00	06/01/2022	
22-05-04580-011	CPS-SB-RM8	05/21/2022	BUBBLER IN ROOM 8	<1.00	06/01/2022	
22-05-04580-012	CPS-SB-RM10	05/21/2022	BUBBLER IN ROOM 10	<1.00	06/01/2022	
22-05-04580-013	CPS-S-SR	05/21/2022	SUN ROOM SINK	<1.00	06/01/2022	

Environmental Hazards Services, L.L.C

Client Number: 201327
Project/Test Address: 220157; Caruso Pre K; 161 Ramsey Avenue;
Keansburg, NJ

Report Number: 22-05-04580

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8
Analyst: Allison Rodriguez
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com



22-05-04580

Due Date:

06/01/2022
(Wednesday)
AE

(Handwritten: OK)

Company Name: LEW CORP Account #: 201327

Address: 181 US Highway 46 City/State/Zip: Mine Hill, NJ 07803

Phone: (908-654-8068) Email: labresults@lewcorp.com Fax: 908-654-8069

Project Name / Collection Address: CAUSO Pre K City/State/Zip: 161 Ramsey Ave Kearsburg, NJ
(Required)

Project #: 220157 Sampled By: Robert Carlucci License # (If Required): _____

Water Source: (Check One) Public X Well _____ Well Tag # (If Applicable): _____
(Required)

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
1	CPS-SB-RM1	Bubbler in Room 1	5-21-22	10:00 AM / PM	X					
2	CPS-SB-RM3	Bubbler in Room 3		AM / PM						
3	CPS-SB-RM5	Bubbler in Room 5		AM / PM						
4	CPS-S-TL	Sink in Teachers Lounge		AM / PM						
5	CPS-S-NO	Sink in Nurse Office		AM / PM						
6	CPS-SB-RM11	Bubbler in Room 11		AM / PM						
7	CPS-SB-RM2	Bubbler in Room 2		AM / PM						
8	CPS-SB-RM4	Bubbler in Room 4		AM / PM						
9	CPS-SB-RM6	Bubbler in Room 6		AM / PM						
10	CPS-SB-RM7	Bubbler in Room 7		AM / PM						

Released by: Robert Carlucci Signature: [Signature] Date/Time: 5-21-22 1:30pm
Released by: AVANDRA Signature: [Signature] Date/Time: 5/24/22 11:30am



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

4580
~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: Caruso Park

City/State/Zip: (Required)

Project #: 220157

Sampled By: Robert Carlucci

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

X	3 Day Turnaround		2 Day Turnaround		2 Day Turnaround		4 Day Turnaround	
---	------------------	--	------------------	--	------------------	--	------------------	--

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
11	CPS-SB-RMG	Bubble no down 8	5-21-22	10:20						
12	CPS-SB-RMG	Bubble no down 10								
13	CPS-S-SL	Sun Room Sink								
14										
5										
6										
7										
8										
9										
10										
Released by: Robert Carlucci		Signature: [Signature]		Date/Time: 5-21-22 1pm						
Released by: AK ANDERSON		Signature: [Signature]		Date/Time: 5/24/22 11:30am						



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 22-05-04584

Received Date: 05/24/2022
Reported Date: 05/31/2022
Sampled By: Robert Carlucci
Tech Certification #:

Project/Test Address: 220157; Keansburg High School; 140 Port Monmouth Road; Keansburg, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04584-001	KHS-S-MO	05/21/2022	MAIN OFFICE SINK	<1.00	05/27/2022	
22-05-04584-002	KHS-S-NO	05/21/2022	NURSE OFFICE SINK	<1.00	05/27/2022	
22-05-04584-003	KHS-WF-105	05/21/2022	WATER FOUNTAIN BY 105	1.94	05/27/2022	
22-05-04584-004	KHS-WC-105	05/21/2022	WATER COOLER BY 105	<1.00	05/27/2022	
22-05-04584-005	KHS-S-RM110	05/21/2022	SINK IN ROOM 110	2.48	05/27/2022	
22-05-04584-006	KHS-WFR-162	05/21/2022	WATER FOUNTAIN BY 162 RIGHT	3.93	05/27/2022	
22-05-04584-007	KHS-WFL-162	05/21/2022	WATER FOUNTAIN BY 162 LEFT	5.02	05/27/2022	
22-05-04584-008	KHS-S1-KIT	05/21/2022	SINK 1 IN KITCHEN	<1.00	05/27/2022	
22-05-04584-009	KHS-S2-KIT	05/21/2022	SINK 2 IN KITCHEN	<1.00	05/27/2022	
22-05-04584-010	KHS-S3-KIT	05/21/2022	SINK 3 IN KITCHEN	1.75	05/27/2022	
22-05-04584-011	KHS-IM-BL	05/21/2022	ICE MACHINE IN BOY'S LOCKER	<1.00	05/27/2022	
22-05-04584-012	KHS-WC-204	05/21/2022	WATER COOLER BY ROOM 204	1.10	05/27/2022	
22-05-04584-013	KHS-WC-CAFE	05/21/2022	WATER COOLER IN CAFETERIA	2.70	05/27/2022	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 22-05-04584

Project/Test Address: 220157; Keansburg High School; 140 Port Monmouth Road; Keansburg, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04584-014	KHS-S-TL	05/21/2022	TEACHER'S LOUNGE SINK	<1.00	05/27/2022	
22-05-04584-015	KHS-PF-KIT	05/21/2022	POT FILLER IN KITCHEN	35.3	05/27/2022	
22-05-04584-016	KHS-S-SR	05/21/2022	SUNROOM SINK	<1.00	05/27/2022	

Method: EPA 200.8

Analyst: Allison Rodriguez

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND

ug/L= micrograms per liter

ppb = parts per billion



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

22-05-04584



Due Date:

06/01/2022

(Wednesday)

AE

(initials)

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: Leansburg High School

City/State/Zip: (Required)

140 Port Monmouth Rd Leansburg NJ

Project #: 220157 Sampled By: Robert Carlucci

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

X

3 Day Turnaround

3 Day Turnaround

2 Day Turnaround

1 Day Turnaround

1 Day Turnaround * Call Ahead

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
1	KHS-S-MO	MAIN OFFICE SINK	5-21-22	8:10	AM/PM					
2	KHS-S-NO	Nurse office SINK			AM/PM					
3	KHS-WF-105	Water fountain by 105			AM/PM					
4	KHS-WC-105	Water cooler by 105			AM/PM					
5	KHS-S-QM110	SINK in Room 110			AM/PM					
6	KHS-WF-162	Water fountain by 162	1st Night		AM/PM					
7	KHS-WF-162	Water fountain by 162	1st Night		AM/PM					
8	KHS-S1-KIT	SINK 1 in Kitchen			AM/PM					
9	KHS-S2-KIT	SINK 2 in Kitchen			AM/PM					
10	KHS-S3-KIT	SINK 3 in Kitchen			AM/PM					
Released by: <u>Robert Carlucci</u>		Signature: <u>[Signature]</u>		Date/Time: <u>5-21-22 10AM</u>		Date/Time: <u>5/24/22 11:30AM</u>				
Released by: <u>AKANDDA</u>		Signature: <u>[Signature]</u>		Date/Time: <u>5/24/22 11:30AM</u>		Date/Time: <u>5/24/22 11:30AM</u>				

P.1



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

4584
~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: Keansburg High School

City/State/Zip: (Required)

Project #: 220157 Sampled By: Robert Carlini

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

X 5 Day Turnaround 4 Day Turnaround 2 Day Turnaround 1 Day Turnaround Call Ahead

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
11	KHS-IM-BL	ICE machine in Boylster S-2122		8:00 AM	X					
12	KHS-WC-204	water cooler by RM 204								
13	KHS-WC-CAT	water cooler in Cafeteria								
14	KHS-S-TL	Teachers lounge SINK								
15	KHS-PF-KIT	Pot Filler in Kitchen								
16	KHS-S-SL	Southern Sink								
8										
9										
10										

Released by: Robert Carlini

Signature:

5/24/22 11:39am

Released by:

Signature:

5/24/22 11:39am



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 22-05-04591
Received Date: 05/24/2022
Reported Date: 05/31/2022
Sampled By: Robert Carlucci
Tech Certification #:

Project/Test Address: 220157; Caruso Elementary School; 81 Frances Place; Keansburg, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04591-001	CE-S-C110	05/21/2022	SINK IN C110	<1.00	05/27/2022	
22-05-04591-002	CE-FP1-KIT	05/21/2022	SINK IN KITCHEN	<1.00	05/27/2022	
22-05-04591-003	CE-PF-KIT	05/21/2022	POT FILLER IN KITCHEN	<1.00	05/27/2022	
22-05-04591-004	CE-S1-KIT	05/21/2022	SINK 1 IN KITCHEN	19.9	05/27/2022	
22-05-04591-005	CE-S2-KIT	05/21/2022	SINK 2 IN KITCHEN	<1.00	05/27/2022	
22-05-04591-006	CE-S3-KIT	05/21/2022	SINK 3 IN KITCHEN	1.06	05/27/2022	
22-05-04591-007	CE-LS-KIT	05/21/2022	LEFT DISHWASH SINK	<1.00	05/27/2022	
22-05-04591-008	CE-RS-KIT	05/21/2022	RIGHT DISHWASH SINK	<1.00	05/27/2022	
22-05-04591-009	CE-SB-B102	05/21/2022	BUBBLER IN ROOM B102	<1.00	05/27/2022	
22-05-04591-010	CE-SB-B106	05/21/2022	BUBBLER IN ROOM B106	<1.00	05/27/2022	
22-05-04591-011	CE-SB-B108	05/21/2022	BUBBLER IN ROOM B108	<1.00	05/27/2022	
22-05-04591-012	CE-WC-100E	05/21/2022	WATER COOLER BY 100E	<1.00	05/27/2022	
22-05-04591-013	CE-BF-100E	05/21/2022	BOTTLE FILL BY 100E	<1.00	05/27/2022	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 22-05-04591

Project/Test Address: 220157, Caruso Elementary School; 81 Frances Place;
Keansburg, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04591-014	CE-WF-100E	05/21/2022	WATER FOUNTAIN BY 100E	<1.00	05/27/2022	
22-05-04591-015	CE-SB-B116	05/21/2022	BUBBLER IN ROOM B116	<1.00	05/27/2022	
22-05-04591-016	CE-WF-A105	05/21/2022	WATER FOUNTAIN IN A105	<1.00	05/27/2022	
22-05-04591-017	CE-WC-A105	05/21/2022	WATER COOLER IN A105	<1.00	05/27/2022	
22-05-04591-018	CE-BF-A105	05/21/2022	BOTTLE FILL IN A105	<1.00	05/27/2022	
22-05-04591-019	CE-S-A104	05/21/2022	SINK IN A104	4.09	05/27/2022	
22-05-04591-020	CE-WC-GYM	05/21/2022	WATER COOLER IN GYM	<1.00	05/27/2022	
22-05-04591-021	CE-WC-C104	05/21/2022	WATER COOLER AT C104	<1.00	05/27/2022	
22-05-04591-022	CE-WF-C104	05/21/2022	WATER FOUNTAIN AT C104	<1.00	05/27/2022	
22-05-04591-023	CE-S-C104	05/21/2022	SINK IN C104	<1.00	05/27/2022	
22-05-04591-024	CE-SB-B101	05/21/2022	BUBBLER IN B101	<1.00	05/27/2022	
22-05-04591-025	CE-SB-B103	05/21/2022	BUBBLER IN B103	<1.00	05/27/2022	
22-05-04591-026	CE-SB-B105	05/21/2022	BUBBLER IN B105	<1.00	05/27/2022	
22-05-04591-027	CE-SB-B107	05/21/2022	BUBBLER IN B107	<1.00	05/27/2022	
22-05-04591-028	CE-WF-A107	05/21/2022	WATER FOUNTAIN BY A107	<1.00	05/27/2022	
22-05-04591-029	CE-WC-A107	05/21/2022	WATER COOLER BY A107	<1.00	05/27/2022	
22-05-04591-030	CE-NS1-A110	05/21/2022	SINK IN NURSE OFFICE	<1.00	05/27/2022	
22-05-04591-031	CE-NS2-A110	05/21/2022	SINK 2 IN NURSE OFFICE	7.67	05/27/2022	
22-05-04591-032	CE-NS3-A110	05/21/2022	SINK 3 IN NURSE OFFICE	1.02	05/27/2022	
22-05-04591-033	CE-WF-B200L	05/21/2022	WATER FOUNTAIN BY B200L	<1.00	05/27/2022	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 22-05-04591

Project/Test Address: 220157; Caruso Elementary School; 81 Frances Place;
Keansburg, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04591-034	CE-WC-B200L	05/21/2022	WATER COOLER BY B200L	<1.00	05/27/2022	
22-05-04591-035	CE-BF-B200L	05/21/2022	BOTTLE FILL BY B200L	<1.00	05/27/2022	
22-05-04591-036	CE-WC-B200G	05/21/2022	WATER COOLER BY B200G	<1.00	05/27/2022	
22-05-04591-037	CE-WF-B200G	05/21/2022	WATER FOUNTAIN BY B200G	<1.00	05/27/2022	
22-05-04591-038	CE-BF-B200G	05/21/2022	BOTTLE FILL BY B200G	<1.00	05/27/2022	
22-05-04591-039	CE-S-B110	05/21/2022	SINK IN B110	1.65	05/27/2022	
22-05-04591-040	CE-WC-B300G	05/21/2022	WATER COOLER BY B300G	<1.00	05/27/2022	
22-05-04591-041	CE-WF-B300G	05/21/2022	WATER FOUNTAIN BY B300G	<1.00	05/27/2022	
22-05-04591-042	CE-BF-B300G	05/21/2022	BOTTLE FILL BY B300G	<1.00	05/27/2022	
22-05-04591-043	CE-WF-B300L	05/21/2022	WATER FOUNTAIN BY B300L	<1.00	05/27/2022	
22-05-04591-044	CE-WC-B300L	05/21/2022	WATER COOLER BY B300L	<1.00	05/27/2022	
22-05-04591-045	CE-BF-B300L	05/21/2022	BOTTLE FILL BY B300L	<1.00	05/27/2022	
22-05-04591-046	CE-BF-A107	05/21/2022	BOTTLE FILL BY A107	<1.00	05/27/2022	
22-05-04591-047	CE-BF-C104	05/21/2022	BOTTLE FILL BY C104	<1.00	05/27/2022	
22-05-04591-048	CE-S-A105	05/21/2022	SINK IN A105	1.06	05/27/2022	
22-05-04591-049	CE-WF-GYM	05/21/2022	WATER FOUNTAIN BY GYM	<1.00	05/27/2022	
22-05-04591-050	CE-SB-B104	05/21/2022	SINK BUBBLER IN B104	<1.00	05/27/2022	
22-05-04591-051	CE-S-SR	05/21/2022	SUN ROOM	<1.00	05/27/2022	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 22-05-04591

Project/Test Address: 220157; Caruso Elementary School; 81 Frances Place;
Keansburg, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Allison Rodriguez

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

5/24/22 11:53am



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

42

4591
~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908-654-8068)

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: Caruso ES

City/State/Zip: 81 Francis Pl Kearsburg, NJ

Project #: 220157 Sampled By: Robert Carucci

License # (if Required):

Water Source: (Check One) Public X Well

Well Tag # (if Applicable):

X 5.00 10.00 15.00 20.00 25.00 30.00 35.00 40.00 45.00 50.00 55.00 60.00 65.00 70.00 75.00 80.00 85.00 90.00 95.00 100.00

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
11	CE-SB-B108	Bottle in Room B108	5-21-22	10:10 AM	X					
12	CE-WC-100E	Water Cooler by 100E								
13	CE-BF-100E	Bottle Fill by 100E								
14	CE-WF-100E	Water Fountain by 100E								
15	CE-SB-B116	Bottle in Room B116								
16	CE-WF-A105	Water Fountain in A105								
17	CE-WC-A105	Water Cooler in A105								
18	CE-BF-A105	Bottle Fill in A105								
19	CE-S-A104	Sink in A104								
20	CE-WC-Gym	Water Cooler in Gym								
Released by: <u>Robert Carucci</u>		Signature: <u>[Signature]</u>		Date/Time: <u>5-21-22 2pm</u>		Date/Time: <u>5/24/22 11:30am</u>				



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

P2

4591
~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908-654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: CAUSO ES

City/State/Zip: 81 GRANCES PL KEANSBURG, NJ

Project #: 20157 Sampled By: Robert Carlsen

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

X	Sub-Territorial	Sub-Territorial	Sub-Territorial	Sub-Territorial	Sub-Territorial
---	-----------------	-----------------	-----------------	-----------------	-----------------

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
21	CE-WC-C104	Water Cooler at C104	5-21-22	10:00 AM	X					
22	CE-WC-C104	Water Cooler at C104								
23	CE-S-C104	Sink in C104								
24	CE-SB-B101	Bottle in B101								
25	CE-SB-B103	Bottle in B103								
26	CE-SB-B105	Bottle in B105								
27	CE-SB-B107	Bottle in B107								
28	CE-WC-A107	Water Cooler by A107								
29	CE-WC-A107	Water Cooler by A107								
30	CE-NSI-A110	SINK IN NUISSE OFFICE								

Released by: Robert Carlsen	Signature: [Signature]	Date/Time: 5-21-22 2pm
Released by: [Signature]	Signature: [Signature]	Date/Time: 5/24/22 11:53am

Released by: Robert Carlini	Signature: [Signature]	Date/Time: 5-28-22 2pm
Released by: AKDnnode	Signature: [Signature]	Date/Time: 5/24/22 11:53am



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

PS

~ For Lab Use Only ~

4591

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908-654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: CAUSO ES

City/State/Zip: 81 FRANCES PL REARSBURG, NJ

Project #: 20157 Sampled By: Robert Carlucci

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

X

EPA 1631

EPA 1631

EPA 1631

EPA 1631

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
41	CE-WF-B3006	Water Fountain by B3006	5-21-22	10:00 AM	X					
42	CE-BF-B3006	Bottle fill by B3006								
43	CE-S-B310	Sink in B310								
44	CE-WF-B300L	Water Fountain by B300L								
45	CE-WC-B300L	Water Cooler by B300L								
46	CE-BF-B300L	Bottle fill by B300L								
47	CE-BF-A107	Bottle fill by A107								
48	CE-BF-C104	Bottle fill by C104								
49	CE-S-A105	Sink in A105								
50	CE-WF-6gym	Water Fountain by 6gym								

Released by: Robert Carlucci

Signature:

MA (G)

Date/Time: 5-21-22

2pm

Released by: ANK ANDOE

Signature:

ANK

Date/Time:

5/24/22 11:53am

Sample NOT received - ANK



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

PL

4591

~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: CARSO ES

City/State/Zip: SE FRANCES PL HEANS BURG, NJ

Project #: 220157

Sampled By: Robert Carlini

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

X

5 DAY TURNAROUND

5 DAY TURNAROUND

2 DAY TURNAROUND

1 DAY TURNAROUND - Call Ahead

No.	Client Sample ID	Collection Location (Exc: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
51	CE-SB-B104	SALESMAN IN B104	5-21-22	10:45 AM	<input checked="" type="checkbox"/>					
52	CE-S-SR	SUN ROOM								
3										
4										
5										
6										
7										
8										
9										
10										
Released by: Robert Carlini		Signature: [Signature]		Date/Time: 5-21-22 3PM						
Released by: AT ANDRE		Signature: [Signature]		Date/Time: 5/24/22 11:53am						



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 22-05-04757

Received Date: 05/25/2022
Reported Date: 06/02/2022
Sampled By: Robert Carlucci
Tech Certification #:

Project/Test Address: 220157; Joseph Bolger Middle School; 100 Palmer Place; Keansburg, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04757-001	JMB-S-NO	05/21/2022	SINK IN NURSE OFFICE	<1.00	06/01/2022	
22-05-04757-002	JMB-IM-NO	05/21/2022	ICE MACHINE IN NURSE OFFICE	<1.00	06/01/2022	
22-05-04757-003	JMB-WC-ONO	05/21/2022	WATER COOLER OUTSIDE NURSE	2.27	06/01/2022	
22-05-04757-004	JMB-WC-AO	05/21/2022	WATER COOLER BY ADMIN OFFICE	2.46	06/01/2022	
22-05-04757-005	JMB-WCL-420	05/21/2022	WATER COOLER LEFT BY ROOM 420	<1.00	06/01/2022	
22-05-04757-006	JMB-WCL-501	05/21/2022	WATER COOLER LEFT BY 501	4.52	06/01/2022	
22-05-04757-007	JMB-WCR-501	05/21/2022	WATER COOLER RIGHT BY 501	1.24	06/01/2022	
22-05-04757-008	JMB-WCL-531	05/21/2022	WATER COOLER LEFT BY 531	<1.00	06/01/2022	
22-05-04757-009	JMB-WCR-531	05/21/2022	WATER COOLER RIGHT BY 531	2.41	06/01/2022	
22-05-04757-010	JMB-WCR-413	05/21/2022	WATER COOLER RIGHT BY 413	<1.00	06/01/2022	
22-05-04757-011	JMB-WCL-413	05/21/2022	WATER COOLER LEFT BY 413	<1.00	06/01/2022	
22-05-04757-012	JMB-WCL-FAC	05/21/2022	WATER COOLER LEFT BY FACULTY	<1.00	06/01/2022	
22-05-04757-013	JMB-S1-KIT	05/21/2022	WASH SINK LEFT KITCHEN	<1.00	06/01/2022	

Environmental Hazards Services, L.L.C

Client Number: 201327
 Project/Test Address: 220157; Joseph Bolger Middle School; 100 Palmer
 Place; Keansburg, NJ

Report Number: 22-05-04757

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04757-014	JMB-S2-KIT	05/21/2022	WASH SINK RIGHT KITCHEN	<1.00	06/01/2022	
22-05-04757-015	JMB-S3-KIT	05/21/2022	BACK WALL SINK KITCHEN	<1.00	06/01/2022	
22-05-04757-016	JMB-PF-KIT	05/21/2022	POT FILLER KITCHEN	53.5	06/01/2022	
22-05-04757-017	JMB-FP-KIT	05/21/2022	FOOD PREP TABLE SINK KITCHEN	1.60	06/01/2022	
22-05-04757-018	JMB-WCL-204	05/21/2022	WATER COOLER LEFT BY 204	<1.00	06/01/2022	
22-05-04757-019	JMB-WCR-204	05/21/2022	WATER COOLER RIGHT BY 204	2.10	06/01/2022	
22-05-04757-020	JMB-WCR-233	05/21/2022	WATER COOLER RIGHT BY 233	2.23	06/01/2022	
22-05-04757-021	JMB-WCL-233	05/21/2022	WATER COOLER LEFT BY 233	<1.00	06/01/2022	
22-05-04757-022	JMB-S1-HE	05/21/2022	HOME EC SINK 1	1.07	06/01/2022	
22-05-04757-023	JMB-S2-HE	05/21/2022	HOME EC SINK 2	<1.00	06/01/2022	
22-05-04757-024	JMB-S3-HE	05/21/2022	HOME EC SINK 3	4.14	06/01/2022	
22-05-04757-025	JMB-S4-HE	05/21/2022	HOME EC SINK 4	3.49	06/01/2022	
22-05-04757-026	JMB-S6-HE	05/21/2022	HOME EC SINK 6	34.2	06/01/2022	
22-05-04757-027	JMB-S7-HE	05/21/2022	HOME EC SINK 7	2.64	06/01/2022	
22-05-04757-028	JMB-WCL-423	05/21/2022	WATER COOLER BY 423 LEFT	2.44	06/01/2022	
22-05-04757-029	JMB-WCL-305	05/21/2022	WATER COOLER BY 305 LEFT	2.34	06/01/2022	
22-05-04757-030	JMB-S-SR	05/21/2022	SUN ROOM	<1.00	06/01/2022	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 22-05-04757

Project/Test Address: 220157; Joseph Bolger Middle School; 100 Palmer
Place; Keansburg, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Allison Rodriguez

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND

ug/L= micrograms per liter

ppb = parts per billion



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

22-05-04757



Due Date:

06/02/2022

(Thursday)

AE

AMK

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908-654-8068)

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address:

Joseph Balger MS

City/State/Zip: 100 Palmer Pl. Hearsburg, MS

Project #: 220157

Sampled By:

Robert Carlson

License # (if Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (if Applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE	
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:		Temp at Time of Receipt:
1	SMB-S-NO	SINK in nurse office	5-21-22	11:00	AM/PM						
2	SMB-IM-NO	ICE MACHINE IN NURSE OFFICE			AM/PM						
3	SMB-UC-OND	WATER COOLER OUTSIDE NURSE			AM/PM						
4	SMB-UC-AO	WATER COOLER by Admin Office			AM/PM						
5	SMB-WCL-410	WATER COOLER Left by RM 410			AM/PM						
6	SMB-WCL-501	WATER COOLER Left by 501			AM/PM						
7	SMB-WCL-501	WATER COOLER Right by 501			AM/PM						
8	SMB-WCL-531	WATER COOLER Right by 531			AM/PM						
9	SMB-WCL-531	WATER COOLER Right by 531			AM/PM						
10	SMB-WCL-413	WATER COOLER Right by 413			AM/PM						
Released by: Robert Carlson					Signature: [Signature]					Date/Time: 5-21-22 3pm	
Released by: AKANDOL					Signature: [Signature]					Date/Time: 5/25/22 10:25am	



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd., Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

92

4757
~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address:

Joseph Balder MS.

City/State/Zip:

150 Palmer Pl Kearnsburg

Project #: 220157

Sampled By: Robert Carlowe

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

X

5 Day Turnaround

5 Day Turnaround

2 Day Turnaround

4 Day Turnaround

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
11	1	SMB-WCL-413	Water cooler, left by 413	5-21-22	10:00 AM					
	2	SMB-WCL-FAC	Water cooler left by facility		AM/PM					
	3	SMB-S1-KIT	WASH SINK LEFT KITCHEN		AM/PM					
	4	SMB-S2-KIT	WASH SINK RIGHT KITCHEN		AM/PM					
	5	SMB-S3-KIT	BACKWASH SINK KITCHEN		AM/PM					
	6	SMB-PF-KIT	PAT FILE KITCHEN		AM/PM					
	7	SMB-FP-KIT	Food Preparation SINK KITCHEN		AM/PM					
	8	SMB-WCL-204	Water cooler left by 204		AM/PM					
	9	SMB-WCL-204	Water cooler right by 204		AM/PM					
20	20	SMB-WCL-233	Water cooler right by 233		AM/PM					
Released by: Robert Carlowe		Signature: [Signature]		Date/Time: 5-21-22 3pm						
Released by: AKANDOL		Signature: [Signature]		Date/Time: 5/25/22 10:25am						



EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form
SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907
ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

4757
~ For Lab Use Only ~

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908-654-8068)

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: (Required)

Joseph Balger MS

City/State/Zip: 100 Palmer Pl Hensburg

Project #: 220157

Sampled By: Robert Carlus

License # (If Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (If Applicable):

X	5-DBA / TUMBING	5-DBA / TUMBING	5-DBA / TUMBING	5-DBA / TUMBING	5-DBA / TUMBING
---	-----------------	-----------------	-----------------	-----------------	-----------------

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters			LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	Temp at Time of Receipt:	
21	SMB-WCL-233	water cooler left by 233	5-21-22	11:00 AM	X						
22	SMB-S1-HE	HOME EC SINK 1									
23	SMB-S2-HE	HOME EC SINK 2									
24	SMB-S3-HE	HOME EC SINK 3									
25	SMB-S4-HE	HOME EC SINK 4									
26	SMB-S6-HE	HOME EC SINK 6									
27	SMB-S7-HE	HOME EC SINK 7									
28	SMB-WCL-423	water cooler by 423 left									
29	SMB-WCL-305	water cooler by 305 left									
30	SMB-S-SL	SUNS ROOM									
Released by: Robert Carlus		Signature: Robert Carlus		Date/Time: 5-21-22 3pm		Date/Time: 5/25/22 10:25am					
Released by: OKANODE		Signature: OKANODE									